



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ತಾಲ್ಲೂಕು ಆರೋಗ್ಯಾಧಿಕಾರಿಗಳವರ ಕಾರ್ಯಾಲಯ

ಹಿರಿಯೂರು-577 598,

ಚಿತ್ರದುರ್ಗ ಜಿಲ್ಲೆ.

Office : 08193-263360

bopmhiriyur@gmail.com

ಸಂ. ತಾ.ಆ.ಹಿ: 1015/2023-24

ದಿನಾಂಕ: 02/06/2023

**PERFORMA REGARDING NOC & SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by Taluk Health Officer, Hiriyyur Taluk, Inspected the **SRI BASAVARAJ ENGLISH MEDIUM HIGH SCHOOL, Alur Channel Road, Near By-Pass, Hiriyyur-577598, Chitradurga District, Karnataka State (Name & Address of the school)** and found that the **SRI BASAVARAJ ENGLISH MEDIUM HIGH SCHOOL** has safe drinking water facilities for the students and members of the institution. And is maintain the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/U.T.Govt.

The above certificate is valid for period of Three Years from the date of issue.

Signature with seal : ತಾಲ್ಲೂಕು ಆರೋಗ್ಯಾಧಿಕಾರಿಗಳು

Name :

Designation :

TALUK HEALTH OFFICER
TALUK HEALTH OFFICE HIRIYUR (T)
CHITRADURGA DIST

To,

Chairman

Sri Basavaraj English Medium High School
Alur Channel Road, Near By-Pass,
Hiriyyur-577598, Chitradurga State,
Karnataka State.

Ranitha

PRINCIPAL

Sri Basavaraj English Medium High School
Aff. Code 831138
Alur channel road, Near Bye-pass,
HIRIYUR -577598,

Srinivas Gowda S.



MANAGING TRUSTEE

Sri Basavaraj Educational Trust
Nrupathunga Extension
HIRIYUR-577 598.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Chitradurga District Water Quality Testing Laboratory
Zilla Panchayath Premesis, Stadium Road, Chitradurga - 577501

TEST REPORT

To Sri Basavaraj English Medium High School Alur Channel Road Hiriyur - 577598 Chitradurga (D) Karnataka Email : sbetprincipal2019@gmail.com Conatct Number: 9740052442				Report date : 06/04/2024 Report Number : 2400021 Reference : TRF Sample receipt date : 05/04/2024 Sample code : CHD2400021 Analysis start date : 05/04/2024 Analysis completion date : 06/04/2024 Sample collection protocol : Not Applicable	
Sample Particulars : Drinking Water, In School				Sample quantity : 1000ml	
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1	pH Value @Temp25°C	8.46	6.5 - 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @Temp25°C	100	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5&6) : 2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
5	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) : 2021
6	Turbidity, NTU	<0.5	1	5	IS 3025 (Part-10) : 2023
7	Total Dissolved Solids@ 180°C, mg/l	53	500	2000	IS 3025 (Part-16) : 2023
8	Alkalinity as CaCO_3 , mg/l	20	200	600	IS 3025 (Part-23) : 2023
9	Total Hardness as CaCO_3 , mg/l	16	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	4.8	75	200	IS 3025 (Part-40) : 1991
11	Magnesium as Mg, mg/l	1.9	30	100	IS 3025 (Part-46) : 2023
12	Chloride as Cl, mg/l	8.0	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as SO_4 , mg/l	4.0	200	400	IS 3025 (Part-24) : 2022
14	Fluoride as F, mg/l	0.33	1	1.5	APHA 24th Edition
15	Nitrate as NO_3 , mg/l	3.1	45	No relaxation	APHA 24th Edition
16	Iron as Fe, mg/l	0.11	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks : The above tested sample meets the requirement of IS 10500:2012 RA 2018 drinking water specification for the above tested parameters only.					
Analysed by :  Junior Analyst : Vinutha			Authorized Signatory :  Technical Manager : Swathi Nadig N P		

RDWSD/WQMSP/TeR/01

NOTE:

01. The above results relate only to the sample tested.
02. The report shall not be reproduced except in full without the prior approval of the Quality Manager.
03. Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
04. Samples will be discarded after 15 days from the date of report generation.
05. Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

-----End of Test Report-----

Ranitha

PRINCIPAL
Sri Basavaraj English Medium High School
Alur Channel Road, Near Bye-pass,
HIRIYUR -577598,

Swathi Nadig N P

MANAGING TRUSTEE
Sri Basavaraj Educational Trust
Nrupathunga Extension
HIRIYUR-577 598